

# Criscuolo Engineering, LLC

---

James M. Pretti, Jr., P.E., L.S., Member  
Robert A. Criscuolo, P.E., L.S., (1957-2018)  
Mark D. Ballou, L.S.  
Charles A. Fisher, L.S.I.T.

Consulting Engineers  
Civil Engineers  
Land Surveyors

## MEMORANDUM

**To:** Kristine Sullivan  
**From:** James M. Pretti, Jr., P.E., L.S., Member  
**Date:** February 13, 2023  
**Re:** 100 Center Road  
Woodbridge, Connecticut  
Proposed Storage Shed  
**CE File No:** 2023.400.02  
**cc:** file

---

Submitted plans and wetland mitigation report for the concrete foundation expansion and new storage building for the Firehouse at 100 Center Road have been reviewed by this office.

The roof drains shall be connected to the existing drainage system.

Erosion Controls are satisfactory and should be installed and inspected by the Town prior to the start of any excavation.

The Wetland Mitigation Report should be made part of the construction documents. All mitigation, plantings and future reporting described in the report should be followed.